

UPS Solutions Back Up Time Calculation Program

BATTERY TIME CALCULATION

ERROR: 4%

| | | | |
|----------------------------------|---------------|----------------|-------------------|
| POWER OF THE MACHINE | 16390 | VA | |
| POWER FACTOR OF THE MACHINE | 0.9 | | |
| LOAD PERCENTAGE | 100 | % | |
| BATTERY NUMBER IN ONE SERIAL ARM | 32 | PCS | |
| NUMBER OF PARALLEL ARM | 1 | PCS | |
| BATTERY CAPACITY | 235 | A/h | |
| BACK UP TIME FROM BATTERY | 262.83 | MINUTES | |
| | OR | 4 hours | 23 minutes |

www.mak-powersis.de

sales@mak-powersis.de / technicalsupport@mak-powersis.de