

UPS Solutions Back Up Time Calculation Program

BATTERY TIME CALCULATION

ERROR: 4%

POWER OF THE MACHINE	15120	VA
POWER FACTOR OF THE MACHINE	1	
LOAD PERCENTAGE	100	%
BATTERY NUMBER IN ONE SERIAL ARM	40	PCS
NUMBER OF PARALLEL ARM	1	PCS
BATTERY CAPACITY	235	A/h

BACK UP TIME FROM BATTERY **335.98** MINUTES

OR **5** hours **36** minutes